



NOTES:

- ① MINIMUM ANGLE BETWEEN INFLUENT AND EFFLUENT PIPES IS 90°, EXCEPT BY SPECIAL DESIGN.
- ② EXCEPTIONS TO THE MINIMUM SEPARATION BETWEEN PIPES WILL BE CONSIDERED PER EACH, BY SPECIAL DESIGN.

EXAMPLE: 48" MANHOLE, EXISTING 24" IN, EXISTING 24" OUT, NEW 18" IN, ALL CONCRETE. MAN-1 TABLE INDICATES A MINIMUM ANGLE OF 80° BETWEEN THE EXISTING 24" (IN) AND THE NEW 18" (IN), RESULTING IN APPROXIMATE 6" OF INTERIOR MANHOLE WALL REMAINING BETWEEN THE 2 PIPES.

DATE
MAY 2004
HANOVER
DPU

MANHOLE SIZING AND MINIMUM ANGLE TABLE

DRWG. NO.
MAN-1
SHT. 2 OF 2