



BELL END ON INCOMING PIPES

PLAIN END ON OUTGOING PIPES

2" CLEARANCE (MAX.)

SEALANT

FLEXIBLE JOINT

CL OF LARGEST PIPE

NOTE: STONE BEDDING SHALL EXTEND TO THE OUTER BOUNDARY OF ALL UNDISTURBED AREAS SURROUNDING THE MANHOLE.

NOTE: BENCH MAY BE CONC. BRICK AND MORTAR.

DATE  
MAY 2004  
HANOVER  
DPU

**STANDARD PRECAST CONCRETE  
MANHOLE SEWERS 8" TO 24"**

DRWG. NO.  
**MAN-2**