



WHERE "A" IS GREATER THAN 2'-0", USE STD. DROP CONNECTION.
 ALL PIPING UTILIZED IN DROP CONNECTION SHALL BE DUCTILE IRON.
 PIPING MAY TRANSITION TO PVC PIPE AT A POINT ONE JOINT AWAY
 FROM THE DROP MANHOLE UNLESS OTHERWISE NOTED ON THE PLANS.

| | | |
|------------------|---------------------------------|---------------|
| DATE MAY 2004 | STANDARD DROP CONNECTION | DRWG. NO. |
| HANOVER DPU | | MAN-10 |